

SECTION 6

6.44 CASING PIPE:

Installation of mains through rights-of-way or easements of others, such as highways, railroads, etc., may require casing pipes for the bores. The type of casing material and its properties will be specified by the agency granting permission to cross. Such crossing shall be subject to approval by Denver Water to avoid conflicts in requirements or standards between Denver Water and the persons or agency granting permission to cross.

Installation of mains through Denver Water rights-of-way or easements may require casing for the bores at the discretion of Denver Water. See Sheets 28 and 29, of the Standard Drawings for details. Final approval of the boring and casing methods and materials shall be obtained from Denver Water prior to construction. Where a bore is not required to cross interference, Denver Water may require the installation of the main under the interference in conformance with Sheet 30 or 31 of the Standard Drawings.